

P.O. BOX 15732 • TAMPA, FLORIDA 33684 • 813/872-7821 CA No. 1450


PROJECT: Product Check

PROJECT NO: 1505.21.1

CLIENT: Pasco Mine

DATE: 01/07/26

LAB NO: B-15863



TEST METHOD:
 AASTHO T-180 Method B

DATE RECEIVED: 12/11/2025
DATE TESTED: 12/30/2025

LOCATION SAMPLED: Stockpile
TYPE OF MATERIAL: Fill
SOIL DESCRIPTION: Gray silty fine SAND

COMPACTION TEST NO: 57
MAXIMUM DRY DENSITY: 113.2 PCF
OPTIMUM MOISTURE CONTENT: 11.7 %



Connie A. Johnson-Gearhart
 CONNIE A. JOHNSON-GEARHART, P.E. 1/19/26
 Florida License No. 69013

This report contains information that is intended solely for the use of the client and noted assigns.
 This report shall not be reproduced, except in full, without written approval of Test Lab, Inc.