

P.O. BOX 16732 • TAMPA, FLORIDA 33684 • 813/872-7821 CA No. 1450


**PROJECT:** Product Check

**PROJECT NO:** 1505.21.1

**CLIENT:** Pasco Mine

**DATE:** 01/07/26

**LAB NO:** B-15862




**TEST METHOD:**  
 AASTHO T-180 Method B

**DATE RECEIVED:** 12/11/2025  
**DATE TESTED:** 12/30/2025

**LOCATION SAMPLED:** Stockpile  
**TYPE OF MATERIAL:** Fill  
**SOIL DESCRIPTION:** Light brown fine SAND

**COMPACTION TEST NO:** 56  
**MAXIMUM DRY DENSITY:** 109.2 PCF  
**OPTIMUM MOISTURE CONTENT:** 11.4 %



*Connie A. Johnson-Gearhart*  
 CONNIE A. JOHNSON-GEARHART, P.E. 1/19/26  
 Florida License No. 69013

This report contains information that is intended solely for the use of the client and noted assigns.  
 This report shall not be reproduced, except in full, without written approval of Test Lab, Inc.