


PROJECT: Product Check **PROJECT NO:** 1505.21.1
DATE: 1/7/2026
CLIENT: Pasco Mine **LAB NO.:** B-15867

SAMPLE LOCATION: Stockpile
SAMPLE DESCRIPTION: Fine Aggregate – Limestone Screenings

<u>Sieve Number</u>	<u>Percent Passing</u>	<u>FDOT Specifications</u> <u>Section 902-5</u>
3/8"	100	100
No. 4	96	75-100
No. 8	80	---
No.16	65	---
No. 30	52	---
No. 50	35	---
No. 100	15	---
No. 200	6.6	---

FINENESS MODULUS: 2.57

DATE SAMPLED: 12/11/2025
DATE RECEIVED: 12/11/2025
DATE TESTED: 12/31/2025
SAMPLED BY: CB
TESTED BY: CB



Connie A. Johnson-Gearhart
CONNIE A. JOHNSON-GEARHART, P.E.
Florida License No. 69013 *1/19/26*